

DVGW-Baumusterprüfzertifikat

DVGW type examination certificate

DG-4513BL0337

Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Gasversorgung <i>products of gas supply</i>
Zertifikatinhaber <i>owner of certificate</i>	HYDROTECHNIK GmbH Holzheimer Straße 94/96, D-65549 Limburg
Vertreiber <i>distributor</i>	HYDROTECHNIK GmbH Holzheimer Straße 94/96, D-65549 Limburg
Produktart <i>product category</i>	pipe equipment and fittings: Test coupling (4513)
Produktbezeichnung <i>product description</i>	test coupling for gas pressure control system to connect a control instrument according to DVGW-working sheet G 491 for pressure measurement and gas und withdrawal of gas
Modell <i>model</i>	1215; 1620
Prüfberichte <i>test reports</i>	supplement test: 09/157/4513/863 from 08.07.2009 (EBI)
Prüfgrundlagen <i>basis of type examination</i>	DVGW VP 604 (01.10.1990)

Ablaufdatum / AZ 19.07.2012 / 09-0451-GNV
date of expiry / file no.

24.07.2009 Rie A 1/2

Datum: Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech) in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik (DATech) in the TGA GmbH for conformity assessment of products of gas and water supply



DAT-ZE-009/96-02

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

Gasart <i>gas category</i>	Bemerkungen <i>remarks</i>
fuel gases according to G260	

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
1215; 1620	nominal pressure rating: PN 100 ambient temperature range: - 20...+70 °C	In the initial type testing of the armature the compression damping was laid at PN 250.

Ausführungsvariante <i>type variation</i>	Erläuterungen <i>explanations</i>
2801-66-33.00	material of the cover: brass, CW 614 N
2701-66-33.00; 2703-66-51.00	material of the cover: stainless steel, material No. 1.4571

zertifizierte Bauteile / Werkstoffe
certified components

Registr.-Nr. <i>registration no.</i>	Bauteil (Produktart) <i>component</i>	Modell/Typ <i>model/type</i>	Hersteller <i>manufacturer</i>
NG-5112BL0012	Sealing material made of elastomers for N7003/N7003 gas appliances		TRELLEBORG SEALING SOLUTIONS Germany GmbH
NG-5112BN0103	Sealing material made of elastomers for N8001/N8001 gas appliances		TRELLEBORG SEALING SOLUTIONS Germany GmbH

Verwendungshinweise / Bemerkungen
hints of utilization / remarks

type of connection für type 1215, variation 2801-66-33.00 and 2701-66-33.00: M 10 x 1 according to DIN 13 with O-ring
type of connection für type 1620, variation 2703-66-51.00: G ¼ with sealing according to DIN EN ISO 228-1

DVGW